

File H100971 - Document CEMATE/3 - Page 1/4

EUROPEAN REACTION TO FIRE CLASSIFICATION REPORT ACCORDING TO THE EUROPEAN STANDARD EN 13501-1

Notified Body by the French State besides the European Commission under number : 0071

Product standard : NF EN 14041
Resilient, textile and laminate floorcoverings

(free translation of French classification report n° H100971 CEMATE/2)

N°H100971 - CEMATE/3

Material submitted by : GERFLOR SA
50 Cours de la République
69627 VILLEURBANNE CX
FRANCE

Commercial trademark : TARALAY MASSIFS COMPACT / TARALAY PREMIUM
(FORUM, METALLICA, FUSION, ARTIC, ZENIUM)

Brief description : PVC floorcovering

Date of report : 2007, October 18th

**Only full reproduction of the present document is authorized.
It contains 4 pages**

1. INTRODUCTION

This classification report defines the classification assigned to product in accordance with the procedures given in EN 13501-1.

2. DETAILS OF CLASSIFIED PRODUCT

2.1. NATURE AND END USE APPLICATION

Type VFHE PVC floorcovering (NF EN 649 standard).

2.2. DESCRIPTION

Product characteristics:

Trademark	Composition	Mass per unit square meter	Thickness
TARALAY MASSIFS COMPACT / TARALAY PREMIUM (FORUM, METALLICA, FUSION, ARTIC, ZENIUM)	Wearing layer : pressed plasticized PVC Backing : reinforced plasticized PVC, calendered	from 2550 to 2650 g/m ² (-10/+13 %)	from 1,00 to 1,25mm from 0,75 to 1,00 mm Total : 2,00 mm (-0.10/+0,13 mm)

Fireproofing : no

Informations given by the sponsor

Text report to be followed on next page

3. TEST REPORTS AND TEST RESULTS IN SUPPORT OF THIS CLASSIFICATION

3.1. TEST REPORTS

Name of laboratory	Name of sponsor	Test report ref. n°	Test method
Laboratoire national de métrologie et d'essais 29 av. Roger Hennequin 78197 TRAPPES CEDEX	GERFLOR SA 50 Cours de la République 69627 VILLEURBANNE CX FRANCE	File : H100971 CEMATE/1	Radiant panel EN ISO 9239-1

3.2. TEST RESULTS FOR FLOORINGS

Test method	Number of tests	Parameters	Results
NF EN ISO 9239-1	1 (6 specimens)	Critical flux (kW/m ²) Smoke (%.min)	10.00 164

Text report to be followed on next page

4. CLASSIFICATION AND DIRECT FIELD APPLICATION

4.1. CLASSIFICATION

Fire behaviour	Smoke production	Flaming droplets
B_{fl}	S1	-

4.2. FIELD OF APPLICATION

This classification is valid for the products mentioned in § 2.2 or strictly and equally stipulated in the quoted production site noted in the test report.

Colour : various

Thickness : about 2 mm

Glued to A1fl or A2fl classified substrates with an acrylic adhesive.

5. LIMITATIONS

5.1. RESTRICTIONS CONCERNING THE VALIDITY PERIOD OF THE CLASSIFICATION REPORT

None.


5.2. WARNING

This document does not represent type approval or certification of the product.


Trappes, the 18th of October 2007

The Head of Fire Behaviour Division

Test officer



Alain SAINRAT



Luc CHEVALIER